




GOVT. OF WEST BENGAL.
OFFICE OF THE EXECUTIVE ENGINEER
JALPAIGURI DIVISION, P.H.E.DTE.JALPAIGURI

JALPAIGURI DIVISIONAL LABORATORY

REPORT OF WATER QUALITY TEST (Chemical & Physical & Bacteriological)

Date of Sample Receiving : 02/08/2026

Date of Sample Testing : 02/08/2026

Ref. of Charges: 192026270158807748

M.R. No. Pg no.006 Book No-11

SL. NO.	NAME OF LOCATION	TYPE OF WATER SOURCE	CHEMICAL & PHYSICAL PARAMETER					BACTERIOLOGICAL PARAMETER (CFU= Colony forming unit)	
			Iron (mg/L)	TDS (mg/L)	Total Hardness (mg/L)	Turbidity (NTU)	pH	T.C (CFU/ 100ml)	F.C (CFU/ 100ml)
1	SHOURYA PUBLIC SCHOOL, TAWA JOTE, RANGAPANI, SILIGURI.	R.O FILTER	0.01	24	44	1.67	6.22	0	0
Permissible Limit for Drinking Water as per IS 10500:2012			1	2000	600	5	6.5-8.5	0	0

N.B: The test done with the sample as deposited by the party.

Depositer name/ Client: PRINCIPAL, SHOURYA PUBLIC SCHOOL, TAWA JOTE, RANGAPANI, SILIGURI.

CHEMIST
DISTRICT WATER TESTING LAB
P.H.E.Dte

BACTERIOLOGIST
DISTRICT WATER TESTING LAB
P.H.E.Dte

JUNIOR ENGINEER
IN CHARGE OF LABORATORY
P.H.E.Dte

ASSISTANT ENGINEER
JALPAIGURI R.W.S. SUB DIVISION,
P.H.E.Dte